



**NOTICE OF AUTHORIZATION TO APPLY THE UL MARK
TO 200KAIC RATED PG, IG AND UG SERIES PRODUCTS**

Northbrook Office

February 18, 2003

MR ROLAND MARCINIAC
INTERMATIC INC
INTERMATIC PLAZA
7777 WINN RD
SPRING GROVE IL 60081

Our Reference: File E89588, Project Number 02NK52793

Subject: 200 KAIC Testing of PG, IG, UG Series

Dear Mr. Marciniac:

On December 30, 2002, we witnessed the 200 KAIC Testing of representative samples of the PG, IG, UG Series of Intermatic products at Allen Bradley's facility in Milwaukee, Wisconsin. The representative samples demonstrated compliant results with the applicable requirements.

This letter temporarily supplements the UL Follow-Up Services Inspection Procedure and serves as authorization to apply the UL Listing Mark to 200 KAIC rated PG, IG, and UG Series products, only at the factories under UL's Follow-Up Service Program, to the above products, which are constructed as described below:

Identical to the subject models which were submitted for this investigation, the UL records covering the product will be in the Follow-Up Services Inspection Procedure, File E89588.

To provide the manufacturer with the intended authorization to use the UL Mark, to 200 KAIC rated PG, IG, and UG Series products, the addressee must send a copy of this Notice and all attached material to each manufacturing location as currently authorized in the appropriate UL File Procedure.

This authorization is effective for 90 days only from the date of this Notice and only for products at the indicated manufacturing locations. Records covering the product are now being prepared and will be sent to the indicated manufacturing locations in the near future. Please note that Follow-Up Services Procedures are sent to the manufacturers only unless the Applicant specifically requests this document.

Products produced, which bear the UL Mark, shall be identical to those evaluated by UL and found to comply with UL's requirements. If changes in construction are discovered, authorization to use the UL Mark may be withdrawn and products that bear the UL Mark may have to be revised (in the field or at the manufacturer's facility) to bring them into compliance with UL's requirements.

Respectfully,

Reviewed by:

David A Gerstetter (Ext. 41733)
Sr. Project Engineer
Conformity Assessment Services - 3013JNBK
E-mail: David.A.Gerstetter@us.ul.com

Dale Hallerberg (Ext. 43224)
Sr. Staff Engineer
Conformity Assessment Services - 3013JNBK
E-mail: Dale.A.Hallerberg@us.ul.com

